


DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT NANGLOI, DELHI-110041



Water Samples collected from "Veda Vyasa D.A.V. Public School" D-Block, Vikaspuri, New Delhi – 110018
Vide challan no:- 94 dated:- 08.07.2024

S1:- Drinking point with (R.O.) at above site.

THE TEST REPORT IS
FOR THIS PARTICULAR
WATER SAMPLE ONLY.

S. No	Parameter	Units	Limit		S1
			Acceptable	Permissible	
PHYSICAL EXAMINATION					
1.	Date of collection	-----	--	--	16.07.2024
2.	Date of Analysis	-----	--	--	18.07.2024
3.	Colour	C.U	5.0	15	Clear
4.	Odour	-----	No. Objectionable		No Obj.
5.	Turbidity	N.T.U.	1.0	5.0	1.1
6.	PH value	-----	6.5	8.5	7.0
7.	Electrical Conductivity	µmho	--	--	188.6
8.	Total dissolved solids	mg/l	500	2000	122.6
CHEMICAL EXAMINATION					
9.	P th Alkalinity	mg/l	--	--	NIL
10.	Total Alkalinity	mg/l	200	600	48
11.	Total Hardness	mg/l	200	600	36
12.	Calcium Hardness	mg/l	--	--	20
13.	Magnesium Hardness	mg/l	--	--	16
14.	Calcium as Ca	mg/l	75	200	8.0
15.	Magnesium as Mg	mg/l	30	100	3.84
16.	Ammonia as N	mg/l	0.5	N.R.	NIL
17.	Nitrite as N	mg/l	--	--	NIL
18.	Nitrate as NO ₃	mg/l	45	N.R.	-
19.	Sulphate	mg/l	200	400	18
20.	Chloride	mg/l	250	1000	28
21.	Dissolved Iron	mg/l	1.0	N.R.	0.04
22.	Fluoride	mg/l	1	1.5	0.10
23.	Cyanide	mg/l	0.05	N.R.	ND
24.	Residual Chlorine	mg/l	0.20 (Min)	1.0	NIL
BACTERIOLOGICAL EXAMINATION					
25.	Coli-form per 100 ml at 37°C	MPN	0		0

REMARKS: As per tested parameters Sample -S1 can be used for drinking purpose

Asst. Chemist
DELHI JAL BOARD
Govt. of N.C.T. Delhi
Quality Control Laboratory
Water Treatment Plant Nanangloi, Delhi-41

BACT.

A/CHEMIST



MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT, WEST ZONE
DR. SAHIB SINGH VERMA NIGAM BHAWAN
SHIVAJI ENCLAVE, RAJA GARDEN, NEW DELHI - 110027



No.DHO/WZ/2024/D- D856

Dated: 09/07/24


HEALTH CERTIFICATE

1. Name of the School Veda Vyasa D.A.V. Public School
2. School address D-Block, Vikaspuri, New Delhi - 110018
3. No of shifts 01 Timings:- 07:30 AM to 2:30 PM
4. No of students:- Boys 2300 Girls 1734 Total 4034
5. No of staff: - Male 34 Female 150 Total 184

Accommodation provide for classroom as under:-

- Floor area in the classroom is sufficient /insufficient Sufficient
- Classes are well lighted/ ill lighted Well lighted
- Classrooms are well ventilated/ill ventilated Well ventilated
- Classes are kept/ not kept neat and clean Neat & clean
- Building/ classrooms require/ do not require white wash etc. not required
- Drinking water is wholesome/ not wholesome wholesome
- Latrine arrangement is sanitary/ insanitary Sanitary from health point of view

Note:- Valid for one year from the date of issue


Dy. Health Officer
West Zone
Dy Health Officer,
West Zone
MCD